

Message Text

CONFIDENTIAL

PAGE 01 FRANKF 04267 261520Z
ACTION SY-05

INFO OCT-01 EUR-12 ISO-00 SYE-00 SSO-00 OC-06 CCO-00
FBOE-00 A-01 /025 W
-----126138 261523Z /42
O 261503Z MAY 78
FM AMCONSUL FRANKFURT
TO SECSTATE WASHDC IMMEDIATE 2077
INFO AMCONSUL LENINGRAD IMMEDIATE

C O N F I D E N T I A L FRANKFURT 4267

DEPT FOR SY/OPS/T; LENINGRAD FOR RSO; FROM AOIC/RTC

E.O. 11652: N/A
TAGS: ASEC
SUBJECT: AIR CONDITIONER FAILURE

REF: LENINGRAD 1576

1. LENINGRAD 1576 FOLLOWS:

2. QUOTE - REQUEST RTC SHIP TO LENINGRAD REPLACEMENT FAN MOTOR FOR
FEDDERS AIR CONDITIONER. REPLACEMENT REQUESTED ASAP SINCE THIS UNIT
COOLS BOTH STATE-CONTROLLED ACRS AT POST. REPLACEMENT IS NOT AVAIL-
ABLE FROM HELSINKI OR MOSCOW.

3. QUOTE - FAILED MOTOR IS GENERAL ELECTRIC, TYPE 5KCP38PG295S,
ONE-HALF HORSEPOWER, 1075 RPM, 208-220 VOLT, 5 AMP, SINGLE PHASE,
60 CYCLE, DOUBLE SHAFT.

4. QUOTE - SHAFT SHOULD EXTEND FROM MOTER SIX INCHES ON ONE END AND
THREE INCHES ON THE OTHER END. A MOTOR WITH DOUBLE SIX INCH SHAFTS
CAN BE CUT TO FIT. MOTOR MOUNTS IN STANFORD FRAME WITH APPROXIMATELY
NINE INCHES BETWEEN BEARINGS.

5. QUOTE - MOTOR IS PART OF FEDDERS A/C UNTI TYPE CACO24A7DC854-
CONFIDENTIAL

CONFIDENTIAL

PAGE 02 FRANKF 04267 261520Z

814. UNQUOTE.

6. RTC FRANKFURT DOES NOT HAVE THE REQUESTED PART. WOULD SY/OPS/T
PLEASE PURCHASE LOCALLY AND FORWARD DIRECTLY TO LENINGRAD.
LEHMANN

CONFIDENTIAL

NNN

Message Attributes

Automatic Decaptioning: X
Capture Date: 01 jan 1994
Channel Indicators: n/a
Current Classification: UNCLASSIFIED
Concepts: n/a
Control Number: n/a
Copy: SINGLE
Draft Date: 26 may 1978
Decaption Date: 01 jan 1960
Decaption Note:
Disposition Action: RELEASED
Disposition Approved on Date:
Disposition Case Number: n/a
Disposition Comment: 25 YEAR REVIEW
Disposition Date: 20 Mar 2014
Disposition Event:
Disposition History: n/a
Disposition Reason:
Disposition Remarks:
Document Number: 1978FRANKF04267
Document Source: CORE
Document Unique ID: 00
Drafter: n/a
Enclosure: DG ALTERED
Executive Order: GS
Errors: N/A
Expiration:
Film Number: D780223-0180
Format: TEL
From: FRANKFURT
Handling Restrictions: n/a
Image Path:
ISecure: 1
Legacy Key: link1978/newtext/t19780516/aaaaamrg.tel
Line Count: 60
Litigation Code IDs:
Litigation Codes:
Litigation History:
Locator: TEXT ON-LINE, ON MICROFILM
Message ID: 11ecb695-c288-dd11-92da-001cc4696bcc
Office: ACTION SY
Original Classification: CONFIDENTIAL
Original Handling Restrictions: n/a
Original Previous Classification: n/a
Original Previous Handling Restrictions: n/a
Page Count: 2
Previous Channel Indicators: n/a
Previous Classification: CONFIDENTIAL
Previous Handling Restrictions: n/a
Reference: 78 LENINGRAD 1576
Retention: 0
Review Action: RELEASED, APPROVED
Review Content Flags:
Review Date: 16 may 2005
Review Event:
Review Exemptions: n/a
Review Media Identifier:
Review Release Date: n/a
Review Release Event: n/a
Review Transfer Date:
Review Withdrawn Fields: n/a
SAS ID: 2555411
Secure: OPEN
Status: NATIVE
Subject: AIR CONDITIONER FAILURE
TAGS: ASEC
To: STATE
Type: TE
vdkgvwkey: odbc://SAS/SAS.dbo.SAS_Docs/11ecb695-c288-dd11-92da-001cc4696bcc
Review Markings:
Sheryl P. Walter
Declassified/Released
US Department of State
EO Systematic Review
20 Mar 2014
Markings: Sheryl P. Walter Declassified/Released US Department of State EO Systematic Review 20 Mar 2014